



TYPE APPROVAL CERTIFICATE
No. MAC287520XG

This is to certify that the product identified below is in compliance with the regulations herewith specified.

<i>Description</i>	Anti-splashing equipment
<i>Type</i>	T-ISS Spraystop standard ; Spraystop 50+
<i>Applicant</i>	T-ISS BV HELMKAMP 34 7091 HR DINXPERLO NETHERLANDS
<i>Manufacturer</i>	T-ISS BV
<i>Place of manufacture</i>	HELMKAMP 34 7091 HR DINXPERLO NETHERLANDS
<i>Reference standards</i>	Chapter II-2 of Solas '74 as amended

Issued in **HAMBURG** on **November 29, 2020**. This Certificate is valid until **February 15, 2026**



RINA Services S.p.A.
Giuseppe Russo

This certificate consists of this page and 1 enclosure

TYPE APPROVAL CERTIFICATE

No. **MAC287520XG**

Enclosure - Page 1 of 1

T-ISS Spraystop standard

Spraystop 50+

Technical characteristics

SPRAYSTOP T-ISS Spraystop standard , Spraystop 50+

Specification:

- Multilayer Aluminium/ Glasscloth/ PET liner with special adhesive.
- Surface printing/ Aluminium foil/ coated layer/ glass fiber layer/ silicon coated layer/ clear PET liner.

Rating:

According to Manufacturer's instructions.

Documents

- Pressure test, Ganewa bv File number 2911/07/2005 dated 28-29-30/11/2005,
- Surface flammability test, FILK (Korea) File number 20050289.

Application limit

Anty-Spray Tape for screening pipe joints and fittings, in piping systems containing oil fuel or other flammable oils, in accordance with IMO SOLAS 74 as amended Regulation II-2/4.2.2.5.3.

The approval is restricted to piping systems which are readily accessible for maintenance and inspection purposes. The SPRAYSTOP anti-splash tape cannot be used for pipes insulation or as replacement for pipe gaskets and sealing.

The Manufacturer has to inform the users about proper methods of application and general maintenance of the SPRAYSTOP anti splash tape.

The installation on-board is to be satisfactorily witnessed by RINA Surveyor for each application on board ships.

HAMBURG November 29, 2020

